

ADDENDUM NUMBER ONE

This addendum shall become a part of the original documents for USPFO Warehouse Remodel, Bldg 6330, Camp Gilbert C. Grafton, Devils Lake, ND, dated 19 February 2018. Acknowledge receipt of this addendum on the bid form.

Current Plan Holders list is attached as Attachment 1.

GENERAL CONSTRUCTION DOCUMENTS

I. GENERAL REQUIREMENTS

Refer to Specification Section 08 3458 – Vault Door

1. 2.01, B – Revise Armory Vault Door to be Class 5-A in lieu of Class 5-V.
2. 2.01, D – Omit and replace Paragraph 3 to read “Mechanical Safe Lock: S&G Model 2937 Mechanical Safe Lock meeting United States Federal Specification FF-L-2937.”

Refer to Specification Section 26 0534 – Conduit

1. 2.01.D - Omit this paragraph in its entirety, rigid conduit will not be required. Replace with “Exposed, Interior, for Intrusion Detection Systems cabling, provide Intermediate Metallic Conduit. See Detail 3/E1.0 on the drawings for additional information.”
2. 2.03 – Omit Paragraph 2.03 Aluminum Rigid Conduit and replace with the following:

2.03 INTERMEDIATE METAL CONDUIT (IMC)

a. Description: NFPA 70, Type IMC galvanized steel intermediate metal conduit complying with ANSI C80.6 and listed and labeled as complying with UL 1242.

b. Fittings:

1. Use fittings complying with NEMA FB 1 and listed and labeled as complying with UL 514B.
2. Material: Steel.
3. Connectors and Couplings: Use compression fittings.
4. Minimum Size: 1/2 inch

Refer to Drawings A3.1 & A3.2

3. Revise size of Vault Door 113 to be 80” x 78” in lieu of 96” x 96”.

END OF ADDENDUM ONE